

Mr. Daniel Gudsell

62 Ascot Road
Mangere
Auckland 2022

Re: Abodo

17th October 2023

Dear Daniel

Please see enclosed the adhesion test report over the supplied Abodo substrate. As expected, coating adhesion levels were excellent, and no concerns were identified during the testing.

As part of this testing, I have spoken with colleagues within Teknos Group regarding wider experiences of a number of thermally modified timber substrates. Responses have confirmed no significant issues being found, although I would highlight an increased propensity for mould growth compared to non-thermally modified substrates. Please note the recommendation for a fungicide in the coating specifications if additional protection is required by the manufacturer. We do have customer experience of thermally modified with Teknos systems being used successfully on Exterior projects.

Please see enclosed our specification for:

- Abodo Exterior Translucent Specification
- Abodo Exterior Opaque Specification

The specifications provided can be issued to customers and where required support is available from our field-based Regional Account Managers.

If you have any further questions, please let me know, but we would be happy to explore the option of an introduction to Abodo by yourselves to our Team at our Bicester facility if this would be of interest?

Kind Regards

David French

WE MAKE THE WORLD LAST LONGER

Teknos GBI (Head Office)
7 Longlands Road
Bicester
OX26 5AH
Tel: +44 (0) 1869 208 005
Email: sales@teknos.co.uk
Web: www.teknos.co.uk