

FC18171-01-1-C1 ASSESSMENT SUMMARY REPORT



This is to certify that the specimen described below have been examined by BRANZ on behalf of the sponsor.

Sponsor

Abodo Wood Limited
62 Ascot Road
Mangere
Auckland, 2022
New Zealand

Reference BRANZ Report

FC18171-01-1 – 11 December 2023

Product Name

Abodo Vaaro™ (ratio I) treated timber with or without Abodo Protector WB Stain

Product as described by the sponsor

18 mm thick solid Flat Sawn or Laminated Vertical Grain (LAMVG) Abodo Vaaro™ (ratio I) timber board with Abodo Protector WB Stain applied according to the manufacturer's specifications in the following colours: White, Clear, Pearl, Patina, Straw, Teak, Walnut, Manuka, Ebony, Graphite, Nero and Natural.

Classification Document	Performance
NZBC Acceptable Solutions C/AS1 in accordance with Table 5.1: Requirements for external wall claddings	PHR < 100 kW/m ² and THR < 25 MJ/m ²
NZBC Acceptable Solutions C/AS2, in accordance with Table C1.3: Classification of cladding materials	Type A
Australian Standard: AS 3959:2018, Appendix F	Bushfire-resisting timber (BAL-29)

Issued by

L. Q. Greive
Associate Fire Testing
Engineer
BRANZ

Reviewed and authorised for release by

L. F. Hersche
Fire Testing Engineer
BRANZ

Regulatory authorities are advised to examine reference reports before approving any product.

Issue Date

11 December 2023